

# ROTORUA LAKES COUNCIL

Te Kaunihera o ngā Roto o Rotorua

## SOLID FUEL HEATER INSTALLATION STATEMENT OF COMPLIANCE

### DETAILS:

Date: \_\_\_\_\_ Building Consent No: \_\_\_\_\_

Installation of: [make] \_\_\_\_\_ [model]: \_\_\_\_\_

Property Address: \_\_\_\_\_  
\_\_\_\_\_

Owners First Name: \_\_\_\_\_ Surname: \_\_\_\_\_

### CHECKLIST:

The above fire was installed according to the manufacturer's specifications, Standard AS/NZS 2918.2001 and the approved Building Consent.

#### It is confirmed that for the installation the following checks were taken:

- Smoke alarms tested and locations checked (3m from each bedroom and on exit path)
- Flashing complies with E2
- Flue extends 600mm above the ridge if within 3m
- Seismic restraints fitted
- Hearth measurement checked and hearth extension fitted if too short
- Flues sealed and fixed with 3 Stainless or Monel fasteners

#### Freestanding Installation

- Inner liner used in ceiling and extending 200mm above roof penetration
- Support stays installed if flue extends more than 1500mm from penetration
- Photos shall be available to confirm compliance with ceiling and roof space framing requirements.

#### Insert Installation

- All cracks in masonry cavity filled with fire resistant sealant or matting
- Chimney swept
- No exposed timber in cavity
- Mantle height checked and mantle reflector installed if too low

Installers Name: \_\_\_\_\_ Signature: \_\_\_\_\_

Registration No: \_\_\_\_\_