

**SOLID FUEL HEATER INSTALLATION  
STATEMENT OF COMPLIANCE**

Ref: IF 05

Ver: 1

Issued: 21 Jan 2014

Doc No: RDC-432013

Page 1 of 1

**DETAILS:**

Date: \_\_\_\_\_ Building Consent No: \_\_\_\_\_

Installation of: [make] \_\_\_\_\_ [model]: \_\_\_\_\_

Property Address: \_\_\_\_\_

Owners First Name: \_\_\_\_\_ Surname: \_\_\_\_\_

**CHECKLIST:**

The above fire was installed according to the manufacturer's specifications, Standard AS/NZS 2918.2001 and the approved Building Consent.

**It is confirmed that for the installation the following checks were taken:**

- ☐ Smoke alarms tested and locations checked (3m from each bedroom and on exit path)
- ☐ Flashing complies with E2
- ☐ Flue extends 600mm above the ridge if within 3m
- ☐ Seismic restraints fitted
- ☐ Hearth measurement checked and hearth extension fitted if too short
- ☐ Flues sealed and fixed with 3 Stainless or Monel fasteners

**Freestanding Installation**

- ☐ Inner liner used in ceiling and extending 200mm above roof penetration
- ☐ Support stays installed if flue extends more than 1500mm from penetration
- ☐ Photos shall be available to confirm compliance with ceiling and roof space framing requirements.

**Insert Installation**

- ☐ All cracks in masonry cavity filled with fire resistant sealant or matting
- ☐ Chimney swept
- ☐ No exposed timber in cavity
- ☐ Mantle height checked and mantle reflector installed if too low

Installers Name: \_\_\_\_\_ Signature: \_\_\_\_\_

Registration No: \_\_\_\_\_