

ROTORUA LAKES COUNCIL

Te Kaunihera o ngā Roto o Rotorua

SOLID FUEL HEATER INSTALLATION STATEMENT OF COMPLIANCE

DETAILS:

Date: _____ Building Consent No: _____

Installation of: [make] _____ [model]: _____

Property Address: _____

Owners First Name: _____ Surname: _____

CHECKLIST:

The above fire was installed according to the manufacturer's specifications, Standard AS/NZS 2918.2001 and the approved Building Consent.

It is confirmed that for the installation the following checks were taken:

- ☐ Smoke alarms tested and locations checked (3m from each bedroom and on exit path)
- ☐ Flashing complies with E2
- ☐ Flue extends 600mm above the ridge if within 3m
- ☐ Seismic restraints fitted
- ☐ Hearth measurement checked and hearth extension fitted if too short
- ☐ Flues sealed and fixed with 3 Stainless or Monel fasteners

Freestanding Installation

- ☐ Inner liner used in ceiling and extending 200mm above roof penetration
- ☐ Support stays installed if flue extends more than 1500mm from penetration
- ☐ Photos shall be available to confirm compliance with ceiling and roof space framing requirements.

Insert Installation

- ☐ All cracks in masonry cavity filled with fire resistant sealant or matting
- ☐ Chimney swept
- ☐ No exposed timber in cavity
- ☐ Mantle height checked and mantle reflector installed if too low

Installers Name: _____ Signature: _____

Registration No: _____