ROTORUA LAKES COUNCIL

Compliance Schedule Details: SS 1 – Automatic Systems For Fire Suppression (e.g. Sprinkler System)						
Please provide the following information with your Building Consent Application - Form 2 If you need help to complete this form, consult the system provider or an IQP who is registered for the system above.						
Applicant Name: Site Address: Existing Compliance Schedule Number(s): <i>(if applicable)</i>				Building Name: Installation provider: <i>(if known)</i> Risk / Purpose group: Fire Hazard Category: Total Occupant Load:		
SPECIFIED SYSTEM DESCRIPTION (address those items that apply)						
Specified systems: Existing New Modified Removed						
Туре:	Image: Image		 Wet pipe-Type Y Foam water 			
		Gas flood fire suppression system				
	□ Foam deluge system: [specify→] □ Non foam enhanced □ Foam enhanced					
	☐ Restaurant suppression system					
Location Plan for specified systems and records is attached: VES NO						
No.	Equipmen	t location	Make (Main co	omponents)	Model	
1						
2						
3						
4						
5						
6				If needed continue th	e list on another sheet of paper	
GTAN		ddraad thaad items that and				
STANDARDS (address those items that apply)(Refer to MBIE <u>CS Handbook</u> 2014)Specifically designed solutions do not apply if the system has been installed against a specific Standard(s) / document.						
Performance / installation:		Image: Solutions do not apply in the System Ind Image:		 Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided). Other: 		
Inspections:		□ NZS 4541, Year: [□ AS 1851, Year: □ NZS 4515, Year:		 Specifically designed solution prepared by a person who, on the basis of experience and qualifications, is competent to do so. (Details provided) Other: 		

Maintenance:	 NZS 4541, Year: AS 1851, Year: NZS 4515, Year: Other: 				
	Continue on the next page				
INSPECTIONS, MAINTENANCE AND REPORTING (address those items that apply)					
Minimum inspection and maintenance procedures:	Planned preventative inspection, maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection Standard/document, to ensure the system will operate as required in the event of a fire.				
Equipment requiring weekly maintenance:	 Building contains Diesel Fire Pump Building contains an Electric Fire pump without an alarm 				
Inspection & Maintenance - frequency and responsibility:	nance - Specifically designed solutions: by IQP only				
Inspections & Maintenance:	 Annual Inspection: The system is connected to the building's emergency warning system therefore testing of the interface between the two systems will be carried out annually. The system is NOT connected to the building's emergency warning system 				
Reporting:	 The owner will keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. These will be recorded in the On-Site Log Book, which will remain on the premises with the most recent compliance schedule, and as a minimum include: Details of any inspection, test or preventative maintenance carried out, including dates, works 				
	undertaken, faults found, remedies applied and the person who performed the work.Form 12A provided annually by the IQP				